

OPERATING EXPERIENCES ON THE FIRST BFB BOILER BURNING BIOMASS FUELS IN POLAND

**Rafał KOBYŁECKI, Robert SEKRET,
Wojciech NOWAK**

Częstochowa University of Technology
Faculty of Environment Engineering and Protection
ul. Dąbrowskiego 69, 42-200 Częstochowa, Poland

**48th IEA – FBC Workshop
'Future Challenges for Waste Combustion and Co-combustion in FBC'
May, 24, 2004, Vienna, Austria**

BIOMASS Utilization Processes

Wet Processes (biological)

Dry Processes (non-biological)

Alcohol
fermentation

No-oxygen
fermentation

Pressure
(Hydrocarbonization)

Pyrolysis

Combustion

Hydro-
generation

Hydro-
gasification

Additional Air
(combustion)

Regulated
atmosphere
(gas generation)

Ethanol

Gases

Gases

Gases

Gases

Gases

Gases

CO

Deposition

Heat

Oil

Ash

Ash

Deposition

Tar

Heat

Biomass Potential & Danger

Low sulfur content (<0.1 %):

less SO₂ emitted compared to coal

‘Zero CO₂ emission’: no carbon tax ?


**ZECA, Los Alamos – any good solution
in general ?**


Other elements: NO_x, DXN ?

**Issue: price/costs of biomass compared
to other fuels**



Ostrołęka Power Station

 **Type: Power Station + Local Heat Station**


 **Fuel: Coal - 1,201,000 t/y
Biomass - 8,000 t/y**

 **Power installed:
724 MW_e + 387 MW_t**

 **Production net:
2179 GWh + 4349 TJ**

 **Market share: 1.8 %
(net, 2003)**

 **Staff: 1,200**




Ostrołęka Power Station consists of:

📄 Heat and Power Station „A”
(since 1956):

367 MW_t heat power,
including 32 MW_t
biomass boiler
75MW_e electric power

📄 Power Station „B”
(since 1972):

1 x 226 MW_e (modernized)
1 x 221 MW_e (modernized)
1 x 200 MW_e



Power Station 'A', Reasons for action toward a BFB at unit #4:



- Utilization of bark produced by neighbouring Intercell Corp.
- Start of fuel diversification at the Power Station
- Introduction of a new combustion technology & maximum utilization of the existing PC boiler equipment
- More environmental friendly operation & adaptation to effective combustion of biomass fuels



Modernization of old PC-fired unit into BFB
done by FOSTER WHEELER Corp. in 1996-1997

Works Performed

- **Manufacturing of biomass and silica sand feeding systems**
- **Modernization of water/steam section of the old boiler, including cutting off of one section of water preheater**
- **Modernization of flue gas outlet system & air preheaters**
- **New lower part of the furnace, including PA nozzles, PA & SA systems and FG recirculation system**
- **Montage of start-up burner and BA drainage system**
- **Installation of automatic microprocessor-based control systems**






BFB at Ostrołęka Power Station, Poland

Bed material:
Silica Sand,
 100 % < 1.2 mm;
 80 % < 0.8 mm
+ Biomass Ash

**Fuel fed from a 14 m³
silo (15-30 min.
of boiler operation)**

| | |
|-------------------------------------|---|
| Type: | Modification of PC unit OP-100 |
| Fuel: | bark, refuse coals |
| Power: | 35 MW_t |
| Steam Flow: | 47 t/h |
| Steam Pressure: | 4 MPa |
| Steam Temperature: | 450°C |
| Gas velocity: | 1 – 1.5 m/s |
| Bed Height: | 0.5 – 1.2 m |
| Chamber width: | 6.05 m |
| Chamber length: | 6.5 m |
| Chamber width at the grate: | 4.19 m |
| Chamber length at the grate: | 6.1 m |
| No. of Nozzles: | 1261 |
| Bed ash drainage ports: | 2 |
| Modification Year: | 1997 |
| Company: | Foster Wheeler |

Schetch of BFB unit at Ostrołęka Power Station



TECHNICAL AND ECOLOGICAL EFFECTS, Modernization of PC OP-100 into BFB

Technical effects:

Higher efficiency

Wider load range

Possibility to burn

low-quality fuels

High availability

Low investment costs

Ecological effects:

280 t/y less SO₂



100 t/y less NO_x

46,000 t/y less CO₂


from fossil fuels

23,000 t/y less hard coal burnt

4,000 t/y less ash



Biomass usage [GJ] Ostrołęka Power Station 'A' 1998-2003



Latest Difficulties:

**Fuel change from Bark
to Wood Chips**

Effect:

**Temperature increase &
Bed agglomeration**

Research (2003.01.20 – 2003.01.25):


Solid samples taken: bottom ash (R & L), backpass ash, fly ash

Fuels burnt:

| | |
|--------------------------------------|--------------------------------------|
| Bark (100%) | 2003.01.20, 0:00 - 2003.01.21, 8:00 |
| Wood chips (100%) | 2003.01.22, 3:00 - 2003.01.23, 15:00 |
| Paper Mill Sludge (40%) + Wood chips | 2003.01.23, 16:00 - 2003.01.24, 8:00 |
| Biosludge I (15%) + Wood chips | 2003.01.24, 9:00 - 2003.01.25, 8:00 |
| Biosludge II (10%) + Wood chips | 2003.01.25, 9:00 - 2003.01.25, 16:00 |

Sampling Time:

20.01.2003, 18:30
22.01.2003, 9:00
22.01.2003, 15:00
22.01.2003, 21:00
23.01.2003, 9:00
23.01.2003, 17:00
23.01.2003, 21:00
23.01.2003, 24:00
24.01.2003, 12:00
24.01.2003, 15:00
25.01.2003, 10:00
25.01.2003, 12:30



Bark



Wood Chips



Paper Mill Sludge



Biosludge I



Biosludge II

Results of Proximate Analysis




As received

| | M _p [%] | M _h [%] | Volat. [%] | Ash [%] | F.C. [%] | C [%] | S [%] | HHV [kJ/kg] | LHV [kJ/kg] |
|-------------------|-----------------------|-----------------------|---------------|------------|-------------|----------|----------|----------------|----------------|
| Silica Sand | 2.7 | 0.1 | | | | | | | |
| Bed ash | 0.05 | 0.2 | | | | | | | |
| Bark | 58.6 | 7.5 | 26.3 | 1.0 | 6.5 | 7.4 | 0.01 | 6240 | 6103 |
| Wood chips | 44.2 | 7.1 | 43.2 | 0.4 | 5.1 | 11.1 | 0 | 8329 | 8213 |
| Paper Mill Sludge | 61.3 | 8.2 | 20.8 | 7.4 | 2.3 | 5.5 | 0.02 | 4017 | 3775 |
| Biosludge I | 43.7 | 7.4 | 42.6 | 0.3 | 5.9 | 12.3 | 0.02 | 8488 | 8361 |
| Biosludge II | 48.1 | 5.9 | 39.9 | 0.7 | 5.4 | 10.1 | 0.03 | 8198 | 8081 |


Air-dried

| | M _p [%] | M _h [%] | Volat. [%] | Ash [%] | F.C. [%] | C [%] | S [%] | HHV [kJ/kg] | LHV [kJ/kg] |
|-------------------|-----------------------|-----------------------|---------------|------------|-------------|----------|----------|----------------|----------------|
| Bark | 58.6 | 7.5 | 71.9 | 2.8 | 17.7 | 20.2 | 0.014 | 17049 | 16674 |
| Wood chips | 44.2 | 7.1 | 82.4 | 0.7 | 9.8 | 21.1 | 0.007 | 15886 | 15664 |
| Paper Mill Sludge | 61.3 | 8.2 | 62.6 | 22.3 | 6.9 | 16.5 | 0.049 | 12094 | 11366 |
| Biosludge I | 43.7 | 7.4 | 80.8 | 0.6 | 11.2 | 23.3 | 0.046 | 16079 | 15838 |
| Biosludge II | 48.1 | 5.9 | 81.6 | 1.3 | 11.1 | 20.7 | 0.064 | 16786 | 16547 |


PSD of Solids




Particle Size Distributions




2003.01.20, 18:30




2003.01.22, 21:00



2003.01.23, 21:00



2003.01.24, 12:00



2003.01.25, 10:00

Ashes: 2003.01.22, 21:00; BFB fired with wood chips



Bed Ash - Right



Bed Ash - Left



Backpass Ash



Fly Ash

Bed Agglomeration Studies:

Combustion of Fuel/Sand mixtures

(El. Oven Nabertherm L3/C6)

Composition of Sand/Fuel Mixtures:

50/50, 20/80 & 5/95

Combustion Time:

2h

Combustion Temperature:

700, 800, 900,
1000 & 1100°C

No Agglomeration found anywhere!

Samples After Combustion



Bark



Wood Chips

**Sand/Fuel Ratio:
5/95**



Paper Mill Sludge



Biosludge I



Biosludge II



Bark



Wood Chips

**Sand/Fuel Ratio:
50/50**



Paper Mill Sludge



Biosludge I



Biosludge II

Temperature: 1100°C, Combustion Time: 2h

CONCLUSIONS

1. BFB at Ostrołęka can be safely fired with bark, wood chips, paper mill sludge, biosludge I & biosludge II
- no agglomeration should occur.
2. Bed temperature should be kept below 900°C. Depending on fuel LHV, the temperature may be regulated by adjusting the air flow, FG flow, BA flow + addition of new sand.
3. PSD of all solids has to be kept within the required values.
4. Maximum size of wood chips should not exceed 4-5 cm.

Agglomeration was due to poor control of fuel feed rate and lack of flue gas recirculation!!

PA & SA flows have to be carefully designed with respect to gas velocity and elutriation.